



**Lesman**  
www.lesman.com

**Instruments • Valves • Controls**

Chicago Area Office  
135 Bernice Dr, Bensenville IL 60106  
Ph: 800-953-7626 • 630-595-8400  
Fax: 630-595-2386

Milwaukee Area Office  
5160 N 125th St, Butler WI 53007  
Ph: 800-837-1700 • 262-923-1790  
Fax: 262-923-1797

E-mail: nathanh@lesman.com

Contact: \_\_\_\_\_ Ext. \_\_\_\_\_

506

V11.2013

Name: \_\_\_\_\_

Company: \_\_\_\_\_

Street: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

E-mail Address: \_\_\_\_\_

Phone: (\_\_\_\_) \_\_\_\_\_ Fax: (\_\_\_\_) \_\_\_\_\_

This is a:  Request for Quote  Order: PO# \_\_\_\_\_

Quantity Needed: \_\_\_\_\_ Date Required: \_\_\_\_/\_\_\_\_/\_\_\_\_

Shipping Method: \_\_\_\_\_ Partials Accepted:  Yes  No

# Liquid Level Bubbler System

## Application Datasheet

### Process Conditions

Tank Depth: \_\_\_\_\_

Media Type: \_\_\_\_\_

Media Specific Gravity: \_\_\_\_\_

Any Moving Parts (Agitator)?  No  Yes

Describe: \_\_\_\_\_

### Build Your Bubbler System

**Step 1:** Pick your enclosure:

- Carbon Steel  Stainless Steel  Fiberglass

Do you need a pole mount kit?  No  Yes

(Available on metal enclosures only.)

**Step 2:** Pick your regulator and coalescing filter:

- 0-60 PSIG air supply regulator with 0.3 micron filter  
 0-60 PSIG air supply regulator with 0.01 micron filter  
*Higher pressure air regulator may be required for greater depths.*

**Step 3:** Pick your HART® smart pressure transmitter:

- 0.4" to 24" WC Siemens DS-III (Accuracy ≤0.075%)  
 4" to 400" WC (33') WC Siemens DS-III (Accuracy ≤0.075%)  
 33' to 133' WC Siemens DS-III (Accuracy ≤0.075%)  
 133' to 275' WC Siemens DS-III (Accuracy ≤0.075%)  
 4" to 400" WC (33') Honeywell ST700 (Accuracy ±0.065%)  
 14' to 275' WC Honeywell ST700 (Accuracy ±0.065%)  
 133' to 275' WC Honeywell ST800 (Accuracy ±0.055%)

**Step 4:** Add a purge/blowdown function to your assembly:

- Pushbutton on Panel Door

**Step 5:** Pick your door-mounted indicator:

- None (Customer supplies power for transmitter)  
 None, 24 VDC Power Supply for Transmitter  
 6-Digit Indicator  
 6-Digit Indicator, 2 Alarm Relays  
 6-Digit Indicator, 4-20 mA Retransmit Output  
 6-Digit Indicator, 2 Alarm Relays, 4-20 mA Retransmit Output  
 6-Digit Indicator, 4 Alarm Relays, 4-20 mA Retransmit Output

**Step 6:** Describe your indicator conditions:

Level Range: \_\_\_\_\_

Level Units: \_\_\_\_\_

Front Panel Label (40 Characters Max): \_\_\_\_\_



*Note:* Customer must supply clean and dry air source plus 120 VAC power (100W) for panel heater and digital indicator.

### Special Instructions/Notes

List any other requirements: