





STANDARD SIZES

PART NO.	A	B	C	D	E	F	MIN. SGT777 V.G. CENTERS (A' DIM)
SINGLE WINDOW GAGES							
FG2004		10.625	6.625				15
FG2005		11.750	7.750				16
FG2006		13.000	9.000				17
FG2007		14.125	10.125				19
DOUBLE WINDOW GAGES							
FG2055		16.000	12.000		3.500		20
FG2066		19.000	15.000		3.000		23
FG2077		21.000	17.000		3.250		25

NOTE: 2" MINIMUM FOR DIMENSIONS 'D' AND 'E'



LIST OF MATERIAL PER WINDOW

ITEM	PART NO.	REQ.	DESCRIPTION	MATERIAL	DWG. NO.
1	FGW-1	1	BODY	STEEL	
2	X173800		STUD 1/2"-20	A-193-B7	
3	FG1500	2	CLAMP	STEEL	A-8585
4	X171510		HEX NUT 1/2"-20	A-194-2H	
5	X174225		WASHER	STEEL	
6	V15841	2	ALUMINOSILICATE GLASS	GLASS	V-15841
7	RWG89	60	SEALING GASKET	GRAFOIL	B-11060
8	V17352	2	CUSHION GASKET	GASKET	V-17352
9	FG621	3	MICA	MICA	B-7701
10	PGW	2	COVER PLATE	STEEL	A-3749U
11	E10	9	HEX PLUG 5/8-18	STEEL	A-6805-5
12	X175500		PLUG GASKET	MONEL	A-5418
13	FG40	8	NAME PLATE	ALUMINUM	A-3876-1
14	PW-33	2	ADAPTOR	304SS	B-14312
15	PW-30	2	PLUG	303SS	B-14312
16	PW-28	2	CONNECTOR	304SS	B-14312
17	RS6477-2	2	FLANGE 1/2"-#2500		A-5819

TO COMPLETE PART NO. * ADD LAST NUMERAL OF INSERT NO.
** ADD INSERT NO.

WORKING STEAM PRESSURE: 2000 PSI

HYDROSTATIC TEST PRESSURE 3000 PSI * TOLERANCES DEFINED BY PES-004

MATERIAL: SEE PES-009

DRAWN: BAC CHECKED:

SCALE: NONE DATE: 4/24/96

REV 1 PER CDC 96-098

(2) CDC04-131 REMOVED SIDE CLEAN OUT CONN. 10/26/04 ST

CLARK-RELIANCE CORP.
STRONGSVILLE, OHIO, U.S.A.

PART NO.: SEE TABLE

FG2000 MICA-PROTECTED
FLAT GLASS GAGES

TOLERANCE CLASS: B

DRAWING
NUMBER:

FG1179-A

REV.

2