

## 301C SPECIFICATIONS

### Controller



#### General Specification

<b>Use</b>	Controller for centralized gas detection monitoring with real-time gas reading, selective alarm activation and low cost installation
<b>Power Requirement</b>	17-27 VAC, 24-38 VDC, 500mA
<b>Size</b>	11 (W) x 8 (H) x 2.8 (D) in. (28 x 20.3 x 7 cm)
<b>Weight</b>	2.4 lbs. (1.1 kg)
<b>Network Capacity</b>	Three RS-485 channels for up to 96 transmitter inputs
<b>Digital Communication</b>	Optional BACnet/IP interface, BTL listed as a smart sensor
<b>Communication Line Lengths</b>	Up to 2,000 ft. (609 m) per channel T-Tap: 65 ft. (20 m), maximum per T-Tap 130 ft. (40 m), maximum for all T-Tap combined
<b>Relay Output</b>	5 A, 30 VDC or 250 VAC (resistive load)
<b>Alarm Levels</b>	Four fully programmable alarm levels
<b>Time Delays</b>	0, 30 sec, 45 sec, 1-99 minutes before and after alarm
<b>Outputs</b>	4 DPDT relays (alarms and/or fault); 65dBA buzzer
<b>Events</b>	Flexible programming that can include: alarms, gas concentrations, faults, real time clock, voting, optional outlier detection, and time since calibration
<b>Display</b>	Large 122 x 32 dot matrix display
<b>Operating Humidity Range</b>	0 to 95% RH (non-condensing)
<b>Operating Temperature Range</b>	-4° to 122°F (-20° to 50°C)
<b>Security</b>	Password protection for tamper resistance
<b>Zoning</b>	Up to 126 programmable zones
<b>Optional Memory</b>	2GB removable SD Card for configuration, readings, and events

#### Ratings and Certification

<b>Certified to</b>	For USA: Safety Requirements for Electrical Equipment for Measurement, Control and Laboratory Use - Part 1: General Requirements (ANSI/UL 61010-1, 2nd Edition, Dated July 12, 2004 Including Revisions Through October 28, 2008) For Canada: Safety Requirements for Electrical Equipment for Measurement, Control and Laboratory Use - Part 1: General Requirements (CAN/CSA C22.2 No. 61010-1:04, 2nd Edition, Dated July 12, 2004 Including General Instruction 1 – October 2008 (Reaffirmed 2009))
<b>Certified by</b>	Intertek
<b>Designed to comply with</b>	IEC 61010-1:2010 (Third Edition) California Title 24, Part 6, and associated administrative regulations In Part 1

#### Find out more

[www.honeywellanalytics.com](http://www.honeywellanalytics.com)

Toll free: 1 800 563 2967

#### Please Note:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or omissions. Data may change, as well as legislation, and you are strongly advised to obtain copies of the most recently issued regulations, standards, and guidelines. This publication is not intended to form the basis of a contract.